

## Facility Summary in RAVALLI County in the City of CORVALLIS

**Location:** THE MERC FRESH MARKET INC  
1000 MAIN ST  
CORVALLIS, MT 59828 RAVALLI

**Sys Fac ID:** 41-02402

**Last Inspected On:** 12/15/2015

**Operating Permit Renewal Date:** 2/17/2019

**Contact:** Jay Joyner, (406) 961-4830

**Owners/Operators:** The Merc Fresh Market Inc, Owner (406)-961-4830 PO BOX 1025  
CORVALLIS MT 59828  
Jay Joyner, UST Class A Operator  
Jay Joyner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	22	2/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
<b>376</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/15/2015	TLS-300 , Veeder Root		
5	19	8/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>377</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		12/15/2015	TLS-300 , Veeder Root		
6	19	8/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>378</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/15/2015	TLS-300 , Veeder Root		

## Facility Summary in RAVALLI County in the City of DARBY

**Location:** MR TS FOOD AND FUEL  
101 S MAIN ST  
DARBY, MT 59829 RAVALLI  
**Contact:** (406) 821-1940

**Sys Fac ID:** 41-00028  
**Last Inspected On:** 1/14/2014  
**Operating Permit Renewal Date:** 5/16/2017

**Owners/Operators:** Floodtide Inc, Owner (406)-821-1940 PO BOX 508  
DARBY MT 59829-0508  
Robert L Flood, UST Class A Operator  
Robert L Flood, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	20	4/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3070</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TS-1000 , Incon		
7	20	4/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3071</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TS-1000 , Incon		

## Facility Summary in RAVALLI County in the City of DARBY

**Location:** DARBY LUMBER  
3299 US HIGHWAY 93  
DARBY, MT 59829 RAVALLI  
**Contact:** Bob Russell, (406) 821-2261

**Sys Fac ID:** 41-00853  
**Last Inspected On:** 4/9/2013  
**Operating Permit Renewal Date:**

**Owners/Operators:**

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	23	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>803</b>			None	None	Yes
Temporarily Out of Use		4/1/2002	Not Required	Safe Suction	Galvanic
Diesel		4/9/2013	Tank Tightness Testing, Inventory Reconciliation	MLLD Line Tightness Testing	
3,000					
5	23	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>804</b>			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		4/9/2013	Manual Tank Gauging, Tank Tightness Testing	MLLD Line Tightness Testing	
1,000					

## Facility Summary in RAVALLI County in the City of DARBY

**Location:** OLES COUNTRY STORE 6  
US HIGHWAY 93 S  
DARBY, MT 59829 RAVALLI

**Sys Fac ID:** 41-10908

**Last Inspected On:** 10/16/2014

**Operating Permit Renewal Date:**

**Contact:** Frank Tabish, (406) 543-7621

**Owners/Operators:** Tabish Brothers Distributors Inc, Owner

(406)-543-7621

GW PETROLEUM  
PO BOX 8448  
MISSOULA MT 59807-8448

Franklin X Tabish, UST Class A Operator

Heather M Stiles, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1441			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Gasoline			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000					
2	20	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1442			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Gasoline			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000					
3	20	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1443			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Diesel			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000					

## Facility Summary in RAVALLI County in the City of DARBY

**Location:** PEOPLES MARKET  
801 N MAIN ST  
DARBY, MT 59829 RAVALLI

**Sys Fac ID:** 56-14029

**Last Inspected On:** 8/29/2013

**Operating Permit Renewal Date:** 12/26/2016

**Contact:** Greg & Jesse Bergren, (406) 821-3612

Owners/Operators: Peoples Market, Owner	(651)-261-3851	801 N MAIN ST DARBY MT 59829-9542
Greg Bergren, Operator	(406)-821-3612	801 N MAIN DARBY MT 59829
Greg Bergren, UST Class A Operator		
Jesse Bergren, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	8/20/2001	Unknown	Flexible Plastic	
<b>4338</b>	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,000					
2	14	8/20/2001	Unknown	Flexible Plastic	
<b>4339</b>	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
4,000					
3	14	8/20/2001	Unknown	Flexible Plastic	
<b>4340</b>	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000					
4	14	8/20/2001	Unknown	Flexible Plastic	
<b>4341</b>	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000					

## Facility Summary in RAVALLI County in the City of FLORENCE

**Location:** DYNA MART LLP  
5323 US HIGHWAY 93 N  
FLORENCE, MT 59833      RAVALLI  
**Contact:** Ivan Lattin, (406) 273-9993

**Sys Fac ID:** 41-11356  
**Last Inspected On:** 11/14/2013  
**Operating Permit Renewal Date:**

**Owners/Operators:** Dich LLP, Owner (406)-273-2512 PO BOX 9  
LOLO MT 59847  
Shannon Tomicek, UST Class A Operator  
Shannon Tomicek, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2331</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
10,000		10/20/2010			
2	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2332</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
12,000		10/20/2010			
3	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2333</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
12,000		10/20/2010			
4	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
<b>2334</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
5,000		10/20/2010			

## Facility Summary in RAVALLI County in the City of FLORENCE

**Location:** TOWN PUMP INC FLORENCE  
5495 US HIGHWAY 93 N  
FLORENCE, MT 59833 RAVALLI  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 41-12720  
**Last Inspected On:** 2/5/2016  
**Operating Permit Renewal Date:** 5/27/2016

**Owners/Operators:** Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Don Edmisten, UST Class A Operator  
Charles A Armstrong, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator  
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2967</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/10/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
9,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
2	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2968</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/10/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
3,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
3	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2969</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/10/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of FLORENCE

**Location:** TOWN PUMP INC FLORENCE  
5495 US HIGHWAY 93 N  
FLORENCE, MT 59833 RAVALLI  
**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 41-12720  
**Last Inspected On:** 2/5/2016  
**Operating Permit Renewal Date:** 5/27/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2970</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/10/2014	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
5	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4192</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4193</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4194</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	



## Facility Summary in RAVALLI County in the City of FLORENCE

**Location:** TOWN PUMP INC FLORENCE  
5495 US HIGHWAY 93 N  
FLORENCE, MT 59833      RAVALLI

**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 41-12720  
**Last Inspected On:** 2/5/2016  
**Operating Permit Renewal Date:** 5/27/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4195</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4196</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4197</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** TOWN PUMP INC HAMILTON 2  
932 S 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-00145  
**Last Inspected On:** 1/18/2016  
**Operating Permit Renewal Date:** 5/27/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Missoula Holdings LLC, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Don Edmisten, UST Class A Operator  
Charles A Armstrong, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator  
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	4/7/1986	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
<b>2593</b>			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/13/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	31	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
<b>2594</b>			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		12/13/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	31	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
<b>2595</b>			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		12/14/2006	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** TOWN PUMP INC HAMILTON 2  
932 S 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-00145

**Last Inspected On:** 1/18/2016

**Operating Permit Renewal Date:** 5/27/2016

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	31	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2596			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/10/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		12/14/2006	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** DAVISONS EXXON SERVICE  
410 S 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-04846

**Last Inspected On:** 6/11/2015

**Operating Permit Renewal Date:** 8/6/2018

**Contact:** Robert Davison, (406) 363-1933

**Owners/Operators:** Davisons Exxon Service, Owner (406)-363-1933 410 S 1ST ST  
HAMILTON MT 59840-2809  
Jack Davison, UST Class A Operator  
Jack Davison, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	22	3/3/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>823</b>	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/3/2009	Deferred	MLLD Line Tightness Testing	
20,000		6/8/2015			
6	22	3/3/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>822</b>	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/23/2009	Deferred	MLLD Line Tightness Testing	
5,000		6/8/2015			
8	22	3/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>821</b>	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2009	Deferred	MLLD Line Tightness Testing	
2,678		6/8/2015			
9	22	3/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
<b>820</b>	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2009	Deferred	MLLD Line Tightness Testing	
7,050		7/21/2011			

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** ANGLERS ROOST LLP  
815 US HIGHWAY 93 S  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-05798

**Last Inspected On:** 7/17/2015

**Operating Permit Renewal Date:**

**Contact:** John G Cawley, (406) 363-1268

**Owners/Operators:** Anglers Roost LLP, Owner (406)-363-1268 815 US HIGHWAY 93 S  
HAMILTON MT 59840-9746

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	4/25/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
<b>3470</b>			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/29/2015	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
10,000					
2	30	4/4/1985	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
<b>3471</b>			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		5/29/2015	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
10,000					

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** RAVALLI COUNTY ROAD DEPT HAMILTON  
244 FAIRGROUNDS RD  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-06546

**Last Inspected On:** 7/10/2013

**Operating Permit Renewal Date:** 8/5/2016

**Contact:** Becky Hankinson, (406) 363-2733

**Owners/Operators:** Ravalli County Sanitarian, Owner (406)-375-6200 205 BEDFORD ST  
HAMILTON MT 59840-2853  
Jim Bryan, UST Class A Operator  
Jim Bryan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	24	11/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1831			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/10/2013	Automatic Tank Gauging 0.2	Deferred	
12,000					

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** TOWN PUMP INC HAMILTON 1  
1117 N 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-09670  
**Last Inspected On:** 1/19/2016  
**Operating Permit Renewal Date:** 5/27/2016

**Contact:** Roger Hovis, (406) 363-4643

**Owners/Operators:** Save O Mat Corporations, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Don Edmisten, UST Class A Operator  
Charles A Armstrong, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator  
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2597</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/15/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2598</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/15/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2599</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/15/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** TOWN PUMP INC HAMILTON 1  
1117 N 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-09670  
**Last Inspected On:** 1/19/2016  
**Operating Permit Renewal Date:** 5/27/2016

**Contact:** Roger Hovis, (406) 363-4643

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2600</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/15/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4490</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4491</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	



## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** MARCUS DALY MEMORIAL HOSPITAL  
1200 WESTWOOD DR  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-12767

**Last Inspected On:** 1/30/2015

**Operating Permit Renewal Date:** 2/13/2018

**Contact:** Gary Schultz, (406) 325-4451

**Owners/Operators:** Marcus Daly Memorial Hospital, Owner (406)-363-2211 1200 WESTWOOD DR  
HAMILTON MT 59840-2345

Eric Etter, UST Class A Operator

Gary Schulz, UST Class A Operator

Eugene Morin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	03	8/1/2012	Concrete	Flexible Plastic	
5376	Yes	8/28/2014	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** RIVERSIDE CONOCO  
1987 N 1ST ST  
HAMILTON, MT 59840 RAVALLI  
**Contact:** (406) 363-3703

**Sys Fac ID:** 41-13588  
**Last Inspected On:** 10/3/2014  
**Operating Permit Renewal Date:** 3/25/2018

**Owners/Operators:** West Fork Holdings LLC, Owner (406)-375-0554 LONE PINE CONOCO  
504 US HIGHWAY 93 S  
HAMILTON MT 59840-8967

Brian R Hawkes, UST Class A Operator  
Steven Hawkes, UST Class A Operator  
Brian R Hawkes, UST Class B Operator  
Steven Hawkes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	17	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3262</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		8/13/2014		Automatic Tank Gauging 0.2	
3	17	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3263</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		8/13/2014		Automatic Tank Gauging 0.2	
4	17	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3264</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		8/13/2014		Automatic Tank Gauging 0.2	

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** RIVERSIDE CONOCO  
1987 N 1ST ST  
HAMILTON, MT 59840      RAVALLI

**Contact:** (406) 363-3703

**Sys Fac ID:** 41-13588  
**Last Inspected On:** 10/3/2014  
**Operating Permit Renewal Date:** 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	10	12/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5061			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		8/13/2014		Automatic Tank Gauging 0.2	

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** Quality Used Cars  
400 N 1ST ST  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 41-13769

**Last Inspected On:** 3/5/2015

**Operating Permit Renewal Date:**

**Contact:** Robert Bapties, (406) 363-0188

**Owners/Operators:** Quality Investments, Owner

(208)-756-2236

PO BOX Q  
SALMON ID 83467

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>3436</b>			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
2	18	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>3437</b>			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
3	18	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>3438</b>			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

## Facility Summary in RAVALLI County in the City of HAMILTON

**Location:** LONE PINE INC  
504 US HIGHWAY 93 S  
HAMILTON, MT 59840 RAVALLI

**Sys Fac ID:** 56-13874

**Last Inspected On:** 12/8/2015

**Operating Permit Renewal Date:** 2/17/2019

**Contact:** Brian R Hawkes, (406) 375-0554

**Owners/Operators:** West Fork Holdings LLC, Owner (406)-375-0554 LONE PINE CONOCO  
504 US HIGHWAY 93 S  
HAMILTON MT 59840-8967

Brian R Hawkes, UST Class A Operator  
Steven Hawkes, UST Class A Operator  
Brian R Hawkes, UST Class B Operator  
Steven Hawkes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	17	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3513</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3514</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	17	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3515</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** THREE MILE TRADING CO  
899 THREE MILE CREEK RD  
STEVENSVILLE, MT 59870 RAVALLI

**Sys Fac ID:** 41-00170

**Last Inspected On:** 12/22/2015

**Operating Permit Renewal Date:** 2/9/2015

**Contact:** Three Mile Trd Company, (406) 777-3365

**Owners/Operators:** Gayla M Cleveland, Owner (406)-777-5153 1407 WHEELBARROW CR RD  
STEVENSVILLE MT 59870  
Russell A Cleveland, Owner (406)-777-5153 1407 WHEELBARROW CR RD  
STEVENSVILLE MT 59870  
Russ Cleveland, UST Class A Operator  
Russ Cleveland, UST Class B Operator  
Russ Cleveland, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
<b>2117</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		
2	22	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
<b>2116</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			Gilbarco EMC Basic , Gilbarco		
4	22	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
<b>2115</b>			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/10/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			Gilbarco EMC Basic , Gilbarco		

## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** EASTSIDE COUNTRY STORE & DELI  
2693 EASTSIDE HWY  
STEVENSVILLE, MT 59870      RAVALLI

**Sys Fac ID:** 41-10286

**Last Inspected On:** 4/29/2014

**Operating Permit Renewal Date:** 9/25/2017

**Contact:** (406) 777-5672

**Owners/Operators:** Eastside Country Store Inc, Owner (406)-777-5672 2693 EASTSIDE HWY  
STEVENSVILLE MT 59870

Julia Cooke, UST Class A Operator  
Clarence Nancy Rainforth, UST Class A Operator  
Julia Cooke, UST Class B Operator  
Clarence Nancy Rainforth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3614</b>	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3615</b>	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
5	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3809</b>	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** MOUNTAIN WEST CO OP STEVENSVILLE  
115 MAIN ST  
STEVENSVILLE, MT 59870 RAVALLI

**Sys Fac ID:** 41-10330

**Last Inspected On:** 6/17/2014

**Operating Permit Renewal Date:** 6/20/2017

**Contact:** Kyle Stensrud, (406) 777-5441

**Owners/Operators:** Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST  
MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator  
Dusty Smith, UST Class A Operator  
John Thompson, UST Class A Operator  
Mary Fleming, UST Class B Operator  
Will Dukart, UST Class B Global Operator  
Dusty Smith, UST Class B Global Operator  
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>911</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>909</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>910</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	



## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** MOUNTAIN WEST CO OP STEVENSVILLE  
 115 MAIN ST  
 STEVENSVILLE, MT 59870 RAVALLI  
**Contact:** Kyle Stensrud, (406) 777-5441

**Sys Fac ID:** 41-10330  
**Last Inspected On:** 6/17/2014  
**Operating Permit Renewal Date:** 6/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>907</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>908</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>906</b>			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	12/29/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>912</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** CJ'S DEN  
324 MAIN ST  
STEVENSVILLE, MT 59870 RAVALLI

**Sys Fac ID:** 41-11429  
**Last Inspected On:** 10/20/2015

**Operating Permit Renewal Date:**

**Contact:** Cody Omlid, (406) 777-2337

**Owners/Operators:** Cody Omlid, Owner (406)-777-2337 324 MAIN STREET  
STEVENSVILLE MT 59870

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
<b>2346</b>			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	MLLD Line Tightness Testing	
6,000					
2	25	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
<b>2347</b>			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	MLLD Line Tightness Testing	
6,000					
3	25	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
<b>2348</b>			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	Vapor Monitoring, MLLD Line Tightness Testing	
2,000					

## Facility Summary in RAVALLI County in the City of STEVENSVILLE

**Location:** OLES COUNTRY STORE 15  
3912 US HIGHWAY 93 N  
STEVENSVILLE, MT 59870 RAVALLI

**Sys Fac ID:** 41-13686

**Last Inspected On:** 2/17/2014

**Operating Permit Renewal Date:** 4/8/2017

**Contact:** Vic Ralls, (406) 777-1179

**Owners/Operators:** Ralls Inc, Owner (406)-777-1179 3912 US HIGHWAY 93 N  
STEVENSVILLE MT 59870-6425  
ROB RALLS, UST Class A Operator  
ROB RALLS, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	5/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3316</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	19	5/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3317</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	19	5/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>3318</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
3,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of SULA

**Location:** SULA COUNTRY STORE LLC  
7060 US HIGHWAY 93 S  
SULA, MT 59871 RAVALLI

**Sys Fac ID:** 41-10411

**Last Inspected On:** 5/21/2013

**Operating Permit Renewal Date:** 10/29/2016

**Contact:** John Kingsbury, (406) 821-1041

<b>Owners/Operators:</b> Thomcorp LLC, Owner	(406)-821-1041	KURT & DEBORAH THOMAS PO BOX 30 SULA MT 59871-0030
Sula Store LLC, Operator	(406)-821-1041	PO BOX 30 SULA MT 59871-0030
John Kingsbury, UST Class A Operator		
Nancy Kingsbury, UST Class A Operator		
John Kingsbury, UST Class B Global Operator		
Nancy Kingsbury, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3485</b>		10/24/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
4	17	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3486</b>		10/24/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					
5	17	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3487</b>		10/24/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					

## Facility Summary in RAVALLI County in the City of SULA

**Location:** LOST TRAIL POWDER MOUNTAIN  
7674 US HIGHWAY 93 S  
SULA, MT 59871 RAVALLI

**Sys Fac ID:** 41-11692

**Last Inspected On:** 9/4/2014

**Operating Permit Renewal Date:** 10/3/2017

**Contact:** (406) 821-3508

**Owners/Operators:** Lost Trail Ski Area Inc, Owner

(406)-821-3211

PO BOX 311  
CONNER MT 59827-0311

Judy Grasser, UST Class A Operator

Scott Grasser, UST Class A Operator

Judy Grasser, UST Class B Operator

Scott Grasser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	1/1/1990	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>2351</b>			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Diesel		9/11/2014	Automatic Tank Gauging 0.2		
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	23	10/1/1992	Steel Clad	No Piping	Flapper Valve (Auto Shutoff)
<b>2352</b>			None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2		
8,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in RAVALLI County in the City of VICTOR

**Location:** VICTOR SINCLAIR  
2381 US HWY 93 N PO BOX 820  
VICTOR, MT 59875 RAVALLI

**Sys Fac ID:** 41-13288

**Last Inspected On:** 1/27/2014

**Operating Permit Renewal Date:** 5/6/2017

**Contact:** Troy Clark, (406) 369-2772

<b>Owners/Operators:</b> GEQ Inc, Owner	(406)-369-2772	PO BOX 820 VICTOR MT 59875
Teresa Clark, Operator	(406)-369-2772	PO BOX 820 VICTOR MT 59875
Troy Clark, Operator	(406)-369-2772	PO BOX 820 VICTOR MT 59875
Teresa Clark, UST Class A Operator		
Troy Clark, UST Class A Operator		
Shean Merwin, UST Class A Operator		
Charles Robinson, UST Class A Operator		
Teresa Clark, UST Class B Operator		
Troy Clark, UST Class B Operator		
Kevin Howe, UST Class B Operator		
Charles Robinson, UST Class B Operator		
Barbara Oliver, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3174</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		
2	22	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3175</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in RAVALLI County in the City of VICTOR

**Location:** VICTOR SINCLAIR  
2381 US HWY 93 N PO BOX 820  
VICTOR, MT 59875 RAVALLI

**Sys Fac ID:** 41-13288

**Last Inspected On:** 1/27/2014

**Operating Permit Renewal Date:** 5/6/2017

**Contact:** Troy Clark, (406) 369-2772

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3176</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		
4	22	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3177</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		

## Facility Summary in RAVALLI County in the City of VICTOR

**Location:** TOWN PUMP OF WOODSIDE  
#6 WOODSIDE CUTOFF RD  
VICTOR, MT 59875 RAVALLI

**Sys Fac ID:** 60-15155  
**Last Inspected On:** 11/2/2015  
**Operating Permit Renewal Date:** 1/31/2019

**Contact:** Doug Dodge, (406) 497-6700

**Owners/Operators:** Manhattan Holdings LLC, Owner (406)-497-6946 PO BOX 6000  
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Charles A Armstrong, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	05	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5241</b>			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	05	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5242</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	05	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5243</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		



## Facility Summary in RAVALLI County in the City of VICTOR

**Location:** TOWN PUMP OF WOODSIDE  
 #6 WOODSIDE CUTOFF RD  
 VICTOR, MT 59875 RAVALLI  
**Contact:** Doug Dodge, (406) 497-6700

**Sys Fac ID:** 60-15155  
**Last Inspected On:** 11/2/2015  
**Operating Permit Renewal Date:** 1/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	05	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5244</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	05	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
<b>5245</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		